

FTV-9 Air Sampling of Elevated Exhaust Duct Locations Conditions

Case No. 1

ICR 56-4.7 (c) (3)

VARIANCE GRANTED. The Petitioner's proposal for eliminated air samples at elevated exhaust locations at the subject premises in accordance with the attached X-page stamped copy of the Petitioner's submittal, is accepted; subject to the Conditions noted below:

THE CONDITIONS

1. Elevated exhaust ducts do not need to be sampled provided there is no access by non-certified personnel to within 25 feet of the end of the duct. Sampling of ground level, roof level and discharge locations adjacent to areas where non-certified personnel have access is required.
2. When air samples are not collected at the exhaust discharge, the sample shall be taken at another project location (e.g. another critical barrier)
3. Usage of this variance is limited to those asbestos removals identified in this variance or as outlined in the Petitioner's proposal.